

AD-755 514

AN ANALYTICAL AND EXPERIMENTAL INVESTI-
GATION OF CABLE RESPONSES TO A PULSED
ELECTROMAGNETIC FIELD

Werner J. Stark

Harry Diamond Laboratories
Washington, D. C.

December 1972

DISTRIBUTED BY:

NTIS

National Technical Information Service
U. S. DEPARTMENT OF COMMERCE
5285 Port Royal Road, Springfield Va. 22151

AD 735518

AD 735518

HOL-TR-1615

AN ANALYTICAL AND EXPERIMENTAL
INVESTIGATION OF CABLE RESPONSES
TO A PULSED ELECTROMAGNETIC FIELD

by

Werner J. Stark

December 1972

D D C
RECEIVED
JAN 10 1973
RECEIVED
B

Reproduced by
**NATIONAL TECHNICAL
INFORMATION SERVICE**
U S Department of Commerce
Springfield VA 22151



HARRY DIAMOND LABORATORIES
WASHINGTON, DC 20435

2/R

UNCLASSIFIED

Security Classification

DOCUMENT CONTROL DATA - R & D

(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)

1. ORIGINATING ACTIVITY (Corporate author) Harry Diamond Laboratories Washington, D.C. 20438		2a. REPORT SECURITY CLASSIFICATION Unclassified	
		2b. GROUP	
3. REPORT TITLE AN ANALYTICAL AND EXPERIMENTAL INVESTIGATION OF CABLE RESPONSES TO A PULSED ELECTROMAGNETIC FIELD			
4. DESCRIPTIVE NOTES (Type of report and inclusive dates)			
5. AUTHOR(S) (First name, middle initial, last name) Werner J. Stark			
6. REPORT DATE December 1972		7a. TOTAL NO. OF PAGES 34	7b. NO. OF REFS 5
8a. CONTRACT OR GRANT NO.		8b. ORIGINATOR'S REPORT NUMBER(S) HDL-TR-1618	
b. PROJECT NO. DA-kW62kk8AD51			
c. AMCMS Code: 502T.11.D5100		9b. OTHER REPORT NO(S) (Any other numbers that may be assigned this report)	
d. HDL Proj: X51E1			
10. DISTRIBUTION STATEMENT			
11. SUPPLEMENTARY NOTES		12. SPONSORING MILITARY ACTIVITY U.S. Army Materiel Command	
13. ABSTRACT An investigation was performed to determine the response of several conductor arrangements to the incident field from the WRF (Woodbridge Research Facility) Biconic radiating antenna. The following measurements are described in this report: <ol style="list-style-type: none"> (1) Open circuit voltage response of a single conductor (2) Current distribution on a single conductor (3) Differential open circuit voltage measurements between two conductors (4) Differential short circuit current measurements between two conductors, In all cases the conductors were parallel to a high conductivity ground plane. An analytical model for computing the response is described, and comparisons are made between computations and measurements. The comparison of theory and experiment shows good agreement for the types of geometric configurations considered in this report.			

DD FORM 1473

REPLACES DD FORM 1473, 1 JAN 64, WHICH IS OBSOLETE FOR ARMY USE.

UNCLASSIFIED
Security Classification

I

UNCLASSIFIED
Security Classification

14 KEY WORDS	LINK A		LINK B		LINK C	
	ROLE	WT	ROLE	WT	ROLE	WT
Electromagnetic pulse	8	3				
Cable coupling	8	3				
Electromagnetic transients	8	3				
Cable modeling	8	3				
Cable tests	8	3				
tl						

UNCLASSIFIED
Security Classification

AD

HDL Project No. X51E1
DA1W62118AD51
AMCMS Code: 502T.11.D5100

HDL-TR-1618

**AN ANALYTICAL AND EXPERIMENTAL
INVESTIGATION OF CABLE RESPONSES
TO A PULSED ELECTROMAGNETIC FIELD**

by

Werner J. Stark

December 1972



U.S. ARMY MATERIEL COMMAND

HARRY DIAMOND LABORATORIES

WASHINGTON, D.C. 20438

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED.

ACKNOWLEDGMENTS

The author would like to thank Mr. Robert Lewis for his assistance in collecting the experimental data, and Mr. Melvin Bostian for his assistance in writing and using a computer code to perform the computations.

Preceding page blank

CONTENTS

ABSTRACT.....	3
1. INTRODUCTION.....	7
1.1 Purpose.....	7
1.2 Approach.....	7
2. CABLE ANALYSIS.....	8
2.1 Test Parameters.....	8
2.2 Analytical Model.....	8
3. EXPERIMENTAL INVESTIGATION.....	12
3.1 EMP Simulator.....	12
3.2 Test Procedures.....	12
4. RESULTS.....	13
4.1 Field Measurements and Computations.....	13
4.2 Cable Response Measurements and Computations.....	13
5. CONCLUSIONS.....	18
5.1 Evaluation of the Description of the Incident Field.....	18
5.2 Evaluation of Transmission Line Theory for Computations of Current and Voltage Responses.....	18
5.3 Instrumentation Problems.....	18
6. RECOMMENDATIONS.....	22
6.1 Improved Computations of the Radiated Field.....	22
6.2 Additional Studies of the Coupling Problem.....	22
GLOSSARY OF TERMS.....	23
APPENDIX A. Voltage and Current Responses of a Two-Wire Transmission Line (Broadside Illumination).....	25

TABLES

I. Test Matrix.....	8
---------------------	---

FIGURES

1. Horizontal electric field component at the monitor point.....	14
2. Open circuit voltage response of a single conductor above the ground plane.....	15
3. Open circuit voltage response of a single conductor above the ground plane (various terminal loads).....	16
4. Current distribution on a single conductor above the ground plane.....	17
5. Differential open circuit voltage at the terminals of a two- wire transmission line.....	19
6. Differential open circuit voltage at the terminals of a two- wire transmission line (poor common mode rejection).....	20
7. Short circuit differential current response at the terminals of a two-wire transmission line.....	21

1. INTRODUCTION

1.1 Purpose

Studies of vulnerability and hardening of military systems to an incident electromagnetic pulse have been pursued to a great extent over the past decade. One of the major problems is to determine the coupling of the electromagnetic field with various system components. In most cases this problem cannot be solved exactly, and various degrees of approximation must be used. It is the purpose of the present study to apply approximate techniques to a specific problem and to determine the extent of validity of the approximations.

The problem of coupling of EMP into cables is one of the most common problems for EMP interaction with military systems, and it is this problem which is considered in this report. In a typical system, cables may lie on the surface of the earth and may have many different orientations. An analytical solution for a randomly oriented cable with twists and turns is practically impossible. Fortunately, from an EMP vulnerability point of view, one is usually interested in maximum responses only. For this case the geometry is greatly simplified.

1.2 Approach

To arrive at a condition for maximum cable response, we can refer to antenna and transmission line theory as well as to empirical data from previous tests on systems. For example, a straight cable far from ground behaves like a short-circuited dipole in free space. From antenna theory it is well known that the maximum current response results for the case of the incident electric field vector being parallel to the dipole. A cable close to a highly conducting ground plane behaves like a two-wire transmission line, the two wires being the cable and its image in the ground plane. From transmission line theory one can show that the maximum response again results from parallel electric field incidence. These conclusions are supported by a multitude of systems tests performed in recent years.

For the purpose of the present report it was desirable to minimize the number of parameters entering into the coupling problem. For a cable above a real earth, two parameters that complicate the analysis are the finite conductivity of the earth and its dielectric constant. The effect of these parameters was eliminated for this study by considering cables above an infinite conductivity ground plane only.

1.2.1 Experimental Techniques

The conductors, whose responses were to be studied, were placed parallel to the major electric field component radiated from the Biconic simulator.¹ The measurements were performed using a wire-screen ground plane directly under the conductors. Current and voltage responses were measured for various types of conductor arrangements and terminal load conditions. Electric field measurements near the location of the cable measurements were made using a SRI field measurement box.¹

¹LANCE Vulnerability and Hardening Report, Test Plan, Annex A - Test Procedures, HDL-TP-2U, 3 April 1972.

1.2.2 Theoretical Techniques

The response of transmission lines to an incident electric field at a given frequency is described in many text books, e.g., Sunde.² The response to a transient incident field can be computed by application of Fourier analysis techniques. The approach used in this report is similar to that described by Putzer.³ The analysis by Putzer is presented in terms of an incident magnetic field, whereas the analysis shown in the appendix is given in terms of the incident electric field. Since the electric and magnetic field components are linearly related, it is easy to show that the two approaches are equivalent.

2. CABLE ANALYSIS

2.1 Test Parameters

The various conductor arrangements and measurements performed are described below in tabular form. Detailed descriptions of these arrangements will be given with the results of the measurements.

Table 1. Test Matrix

CABLE TYPE	PARAMETERS VARIED	LOAD CONDITIONS	TYPE MEASUREMENT
Single Conductor	Diameter, Length, Height Above Ground Plane, Load Conditions	Open Circuit, Resistive, Capacitive and Inductive Loads	Voltage to Ground, Current Distribution
Two Wires	Height Above Ground Plane, Separation Between Wires, Load Conditions	Open Circuit Resistive, Capacitive and Inductive Loads	Open Circuit Voltage, Short Circuit Current

2.2 Analytical Model

2.2.1 Horizontal Radiated Electric Field at the Test Site

It is well known from basic antenna theory that in the far field the major radiated electric field component is parallel to the radiating antenna. Because the Biconic radiating antenna is parallel to the ground, this major component is commonly referred to as the horizontal electric field. At the test site, the electric field is the algebraic sum of the free field and the reflected field. The reflection coefficient for a horizontally polarized electric field is given by⁴

² E. D. Sunde, *Earth Conduction Effects in Transmission Systems*, Dover Publications, Inc., New York (1967).

³ E. J. Putzer, *Theory of the Driven Two-Wire Transmission Line*, prepared by American Nucleonics Corporation for USAMERDC, February 1969.

⁴ S. A. Schelkunoff and H. T. Friis, *Antennas Theory and Practice*, John Wiley & Sons, Inc., New York, London, Sydney, 1966.

$$R_E = \frac{\sin \Delta - (\epsilon_r - \cos^2 \Delta - j60g\lambda)^{1/2}}{\sin \Delta + (\epsilon_r - \cos^2 \Delta - j60g\lambda)^{1/2}} \quad (1)$$

The ground conductivity, g , for soil is in the order of 0.001 to 0.02 mho/m and the dielectric constant for moist soil is in the order of 20 (ref. 4). Then for small angles of incidence, Δ , and short wave lengths, λ , the reflection coefficient is given by $R_E \approx -1$. Using this value of R_E the expression for the net electric field at the test site can be written as:

$$\begin{aligned} E_H(t) &= E_{OH}(t) & 0 < t < t_d \\ E_H(t) &\approx E_{OH}(t) - E_{OH}(t - t_d) & t > t_d \end{aligned} \quad (2)$$

where E_{OH} is the horizontal radiated free field at the test point, and the delay time, t_d , is fixed by the relative positions of the antenna, ground plane and test point.

For an EMP coupling analysis one must have detailed knowledge of of the incident electromagnetic field. At several feet above ground, field measurements can be made directly with a field measurement box. At points close to ground, the field waveshape must be estimated from an expression such as eq (2). Direct measurement of the radiated free field, E_{OH} , is impossible due to the presence of the ground. It can be determined indirectly, however, from measurement of certain field components. By considering the reflection of an electromagnetic plane wave incident on the ground at small angles, one can show that near ground the horizontal electric free field is related to the horizontal component of the net electric field and the radial component of the net magnetic field by:

$$E_{OH}(t) \approx \frac{E_H(t)}{2} + \frac{60\pi R}{h'} H_R(t) \quad (3)$$

In this expression, R is the distance from the base of the Bicone, h' is the height of the Bicone above ground, while E_H and H_R are the horizontal and radial components of the net electric and magnetic fields, respectively, at the test point.

2.2.2 Current and Voltage Distribution on a Single Conductor Above the Ground Plane

The derivation of the response of a two-wire transmission line to an incident electromagnetic field is presented in appendix A. The discussion in the appendix shows how the solution can be applied to obtain the response of a single conductor above a ground plane of infinite conductivity. The response to an incident electromagnetic field whose electric field vector is parallel to the conductor is given by:

$$i(x) = \frac{E_H}{4\Gamma Z_0} \left\{ 2 - (1+R_1)e^{-\Gamma x} - (1+R_2)e^{-\Gamma(\ell-x)} + R_1(1+R_2)e^{-\Gamma(\ell+x)} \right. \\ \left. + R_2(1+R_1)e^{-\Gamma(2\ell-x)} - 2R_1R_2e^{-2\Gamma\ell} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (4)$$

$$V(x) = \frac{E_H}{4\Gamma} \left\{ -(1+R_1)e^{-\Gamma x} + (1+R_2)e^{-\Gamma(\ell-x)} + R_1(1+R_2)e^{-\Gamma(\ell+x)} \right. \\ \left. - R_2(1+R_1)e^{-\Gamma(2\ell-x)} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (5)$$

Consider the case of a cylindrical conductor of radius a , suspended at a height h , parallel to the ground plane. The characteristic impedance (far from the ends of the conductor) is given by (ref. 4):

$$Z_0 = 60 \ln \frac{2h}{a} \quad (a \ll h) \quad (6)$$

The propagation constant, Γ , is computed from Equation (A-4). For a transmission line with small losses the propagation constant becomes⁵

$$\Gamma(\omega) = \frac{j\omega}{v} + \alpha \quad (7)$$

where v is the propagation velocity along the conductor, ω , is the frequency in radians, and α takes into account the losses resulting from series impedance and shunt admittance along the conductor.

The reflection coefficients R_1 and R_2 are computed from eq (A-14) and (A-15). The required value of Z_0 is computed as shown above and the impedances Z_1 and Z_2 are the impedances to ground at the conductor terminals.

Equations (4) and (5) give the responses at a particular frequency, ω . To obtain a transient solution, one must apply Fourier or Laplace Transform techniques.

2.2.3 Current and Voltage Response at the Terminals of a Two-Wire Transmission Line in Free Space

The solutions derived in the appendix give the current and voltage distributions along the transmission line. In general, one is interested only in the response at the terminals. Consider the case

⁵W. T. Scott, The Physics of Electricity and Magnetism, John Wiley & Sons, Inc., New York, 1959.

for which the incident electromagnetic field has the electric field vector parallel to the transmission line. From eq (A-16) and (A-17), the responses at the terminals are given by:

$$I(o) = \frac{E_H(1-R_1)}{2\Gamma Z_0} \left\{ 1 - (1+R_2)e^{-\Gamma d} e^{-2\Gamma l} \right\} / (1-R_1 R_2 e^{-2\Gamma l}) \quad (8)$$

$$V(o) = I(o)Z_1 \quad (9)$$

Approximate expressions for characteristic impedances of transmission lines are given in many textbooks, e.g., Scott.⁵ The characteristic impedance (far from the ends of the line) for a two-wire transmission line is:

$$Z_0 = 120 \ln \frac{d}{a} \quad (2a \ll d) \quad (10)$$

where d is the center to center separation of the wires, and a is the radius of each wire.

The propagation constant, Γ , and the reflection coefficients R_1 and R_2 are computed as described in Section 2.2.1. The electric field to be used in eq (9) is the difference between the electric fields incident on the two wires at a given time (see appendix). Consider the case where the velocity vector of the incident electric field is perpendicular to the line and is in the plane of the two wires. For this configuration, the time delay for the field incident on the two wires is:

$$t_d = \frac{d}{v} \quad (11)$$

where v is the propagation velocity of the electromagnetic field. A delay of t_d for a function $E(t)$ can be represented in the frequency domain using straightforward Fourier transform techniques. Then E_H in equation (8) becomes:

$$E_H(\omega) = E_O(\omega) (1 - e^{-j\omega t_d}) \quad (12)$$

where $E_O(\omega)$ is the Fourier transform of the electric field vector incident on one line.

2.2.4 Current and Voltage Response at the Terminals of a Two-Wire Transmission Line Above a Ground Plane

In practice, one encounters the case in which the transmission line is suspended at some height above the ground plane. In this case, the response can be interpreted in terms of two different modes of

propagation on the line. One is that between the transmission line and ground, sometimes referred to as common mode; the other is that between the two conductors of the line, sometimes referred to as the differential mode.

For a vulnerability analysis one may be interested in either of these two modes, depending on the terminations. If the terminal load condition consists of an impedance path to ground, then the common mode is of interest. If, on the other hand, the load impedance appears only across the two conductors, then the differential mode is to be determined.

The common mode response can be computed approximately by using a modification of the analysis for a single conductor above ground. The modification consists basically of replacing the computation for the characteristic impedance from that of a single wire above ground to that of a two-wire transmission line above ground.

Except for the proximity of the ground plane, the differential mode is similar to the response of a transmission line in free space. The effect of the ground can be taken into account approximately by using the total field (sum of incident and reflected) as the driving field for the transmission line.

3. EXPERIMENTAL INVESTIGATION

3.1 EMP Simulator

The antenna used for producing the radiated electromagnetic fields in the present investigation was the Biconic antenna at the Woodbridge Research Facility (WRF). A detailed description of this antenna is presented in reference 1. Basically, the Biconic antenna system is a horizontal dipole radiator capable of producing a maximum free field of approximately 6kV/m at a point 90 m away from the antenna in its normal operating mode. Some typical waveforms of the net radiated electric field from the Bicone are shown in Section 4.1.

3.2 Test Procedures

The conductors to be tested were placed along the perimeter of a circle whose center was at the center of the Bicone. With this geometry the initial radiated wavefront from the Bicone would arrive at all portions of the conductors simultaneously. The distance from the base of the Bicone to the conductors was 110 m. The conductors were placed near the Biconic plane of symmetry. A wire screen was placed on the ground in the area underneath the conductors to simulate an ideal ground plane. The specific geometry for each test will be described in section 4.

Current measurements were made using a shielded Tektronix P-6020 current probe. Single-ended voltage measurements were made with a shielded Tektronix P6047 probe, and differential voltage measurements were made using a shielded Tektronix P6046 differential voltage probe. The data were recorded on Polaroid film using a Tektronix 454 scope with a C-40 camera and scope attachment.

3.2.1 Measurements of the Radiated Field

The radiated horizontal electric field component was measured using an SRI field measurement box (ref. 1). The field was measured

at several locations near the test site. Since the net horizontal electric field component varies considerably as a function of height above the ground plane, measurements of this field component were made at a range of heights above ground.

3.2.2 Measurements on a Single Wire Above the Ground Plane

A single conductor, 23 feet in length, was supported at several different heights above the ground plane. Open circuit voltage measurements to ground were made at each height. With the conductor 4.6 inches above ground, the open circuit voltage was measured at one end with several different terminal load conditions at the other.

3.2.3 Measurements on a Two-Wire Transmission Line Above the Ground Plane

The two conductors of a pair of field wires were supported at different heights above the ground plane and various spacings between the conductors. Voltage and current measurements at the terminals were made for a variety of load conditions between the two field wires.

4. RESULTS

4.1 Field Measurements and Computations

4.1.1 Horizontal Radiated Electric Field Component

Figure 1 shows the horizontal electric field component at two different heights above ground at the monitor point. (This point is located at 60 m from the base of the Biconic on the plane of symmetry.) The computations for the field were made from equation (2) using experimental data for E_H and H_R . Measurements and computations for the electric field close to the test site resulted in a comparison similar to that shown in figure 1.


4.2 Cable Response Measurements and Computations

4.2.1 Open Circuit Voltage of a Single Conductor Above the Ground Plane


Figures 2 and 3 show the open circuit voltage of a single conductor above a wire screen ground plane. Figure 2 shows the variation in the response as a function of the conductor height above the ground plane. Figure 3 shows the response for several types of terminations at one end of the conductor. The computations were made using equation (5) with $x = 0$ and $\alpha = 0.01\text{m}^{-1}$. This value of α was used to fit the computed attenuation of the response to the experimental data.

4.2.2 Current Distribution on a Single Conductor Above the Ground Plane

Figure 4 shows the current response of a single conductor at a height of 30 in. above the ground plane. The responses are shown for a position, x , along conductor where $x = l/2$ and $l/4$. The computations were made using equation (4) with $\alpha = 0$, i.e., no attempt was made to take attenuation into account. According to this expression the current should be zero at the ends of the conductor. This result was verified with current measurements at the ends (data not shown).



(a) Experimental Data



(b) Computed Field

Figure 1. Horizontal electric field component at the monitor point.







Figure 2. Open circuit voltage response of a single conductor above the ground plane.




$C = 23 \text{ pf}$

$L = 50 \mu\text{h}$

50V/div
 V_{OC}





50V/div



Time (20ns/div)



(a) Experimental Data




Time (ns)

(b) Computed Response

Figure 3. Open circuit voltage response of a single conductor above the ground plane (various terminal loads).



(a) Experimental Data



(b) Computed Response

Figure 4. Current distribution on a single conductor above the ground plane.

4.2.3 Differential Voltage at the Terminals of a Two-Wire Transmission Line

Figure 5 shows the response for the differential voltage at the terminals of a two-wire transmission line. The computations for the response were made using eq (9) with $\alpha = 0$. To illustrate some problems which may be encountered when using a differential voltage probe, figure 6 shows a partly erroneous differential voltage measurement. (See section 5 for a discussion of this problem.)

4.2.4 Differential Current at the Terminals of a Two-Wire Transmission Line

Figure 7 shows the short circuit current at the terminals of a two-wire transmission line. The computations were made using eq (8) with $\alpha = 0$.

5. CONCLUSIONS

5.1 Evaluation of the Description of the Incident Field

The computation of the net electric field as discussed in section 2 is based on information about the electric free field radiated from the Bicone. This information can be extracted from measurements of E_H and H_R . The validity of this approach has been supported by comparing computations with experimental data: (1) The computed horizontal electric field at different heights above ground agreed well with measurements. (2) Calculations of currents and voltages on conductors with the computed field for the driving source compared well with measurements.

5.2 Evaluation of Transmission Line Theory for Computations of Current and Voltage Responses

The good agreement between computations and measurements support the analytical approach described in section 2. For the geometries considered, the horizontal electric field component can be viewed as the major driving field for the coupling problem.

Errors can be introduced in the computation of the response of conductors close to the ground plane. These errors arise primarily as a result of difficulties in accurately computing the incident field close to ground. Some of these difficulties can be removed by accurately determining the radiated free field (section 6).

5.3 Instrumentation Problems

Sometimes it may happen that the instrumentation used for measuring the responses will record an incorrect result. It may be difficult to recognize such an error unless one knows what kind of response is expected. This is one of the reasons why an understanding of the coupling problem is important.

An example of the type of problem which may be encountered is shown in figure 6. This figure shows the measured differential voltage for two different separations of the transmission line. Computations show that the result should be such as shown in figure 5 with the two measurements differing in amplitude only. The data in figure 6 clearly shows a common mode signal superimposed on the differential signal, indicating a problem with the DV probe. (The measurement shown in figure 5 was made with a second DV probe.)






Figure 5. Differential open circuit voltage at the terminals of a two-wire transmission line.



$d = 9$ in



$d = 19$ in







Figure 6. Differential open circuit voltage at the terminals of a two-wire transmission line (poor common mode rejection).



(a) Experimental Data



(b) Computed Response

Figure 7. Short circuit differential current response at the terminals of a two-wire transmission line.

6. RECOMMENDATIONS

6.1 Improved Computations of the Radiated Field

Accurate information about the radiated free field from the Bi-cone is required to correlate the Biconic free field to another field, such as the threat field for example. It can also be used for computing the net field at any point by applying the methods described in section 2. Better estimates of the radiated free field could be made by measuring the required E_H and H_R components at several points, computing the free field and averaging the results.

6.2 Additional Studies of the Coupling Problem

The work described here considered the coupling problem for the case of an infinite conductivity ground plane only. In a practical situation, cables will be positioned above a finite conductivity ground plane. Hence, it is important to address this problem.

Obviously, the analytical work required is much more extensive in the latter case than in the former case. Sunde (ref. 3) has outlined approximate solutions for the finite conductivity case. His basic approach is to compute modifications to the propagation constant and to the characteristic impedance, and apply the modified parameters to the usual transmission line equations. A comparison of theory and experiment would permit a useful evaluation of Sunde's approximate solutions.

GLOSSARY OF TERMS

a	Radius of Conductor	L	Inductance
C	Capacitance	R	Distance from Center of Biconic to Test Point
d	Perpendicular Distance Between Two Wires	R_1	Reflection Coefficient at Probe End
DI_{SC}	Differential Short Circuit Current	R_2	Reflection Coefficient at End Away From Probe
DV_{OC}	Differential Open Circuit Voltage	R_E	Earth Reflection Coefficient for Horizontal Electric Field Component
E_H	Net Horizontal Electric Field Component	t_d	Time Delay for Propagation Between Two Wires Spaced a Distance, d , Apart
E_{OH}	Horizontal Electric Field Component of the Free Field	v	Velocity of Propagation
E_V	Vertical Electric Field Component	V_{OC}	Open Circuit Voltage
g	Ground Conductivity	$V(x)$	Voltage Distribution on Conductor Above Ground
h	Height of Conductor Above Ground	Y	Transverse Admittance Per Unit Length Along a Two Wire Transmission Line
h'	Height of Biconic Above Ground	Z	Impedance Per Unit Length Along a Two Wire Transmission Line
H_R	Radial Magnetic Field Component	Z_1	Impedance at Probe End
H_V	Vertical Magnetic Field Component	Z_2	Impedance at End Away from Probe
$I(x)$	Current Distribution on Conductor Above Ground	Z_0	Characteristic Impedance
$J(x)$	Transverse Current Distribution Between the Two Conductors of a Transmission Line		

α	Attenuation Constant
Γ	Propagation Constant
Δ	Angle of Incidence
ϵ_r	Relative Dielectric Constant
λ	Wave Length
ω	Radial Frequency

APPENDIX A. Voltage and Current Response of a Two-Wire Transmission Line (Broadside Illumination)

Broadside illumination refers to the condition in which the velocity vector of the incident electromagnetic field is perpendicular to the transmission line. The general solution to this problem is discussed in many textbooks. The discussion presented here follows the approach described by Sunde.¹

Consider a short segment of a transmission line as shown in figure A-1. The voltage, $V(x)$, is the voltage of line 2 at a point x with respect to line 1 at that point. The current, $I(x)$, at the point x , is equal in magnitude on both lines but opposite in direction. The basic differential equations for current and voltage along the transmission line are:

$$\frac{dI}{dx} = -YV \quad (A-1)$$

and

$$\frac{dV}{dx} = -ZI \quad (A-2)$$

A general solution for current and voltage must be considered for two different cases.

CASE I - Incident Electric Field Vector Parallel to the Transmission Line

One obtains the solution to this problem by computing the response to the incident field on each line separately and using superposition to get the total response. If an electric field distribution, $E_H(x)$, is incident in the x direction along line 2, eq (A-2) must be modified to include $E_H(x)$ as a source term. With this modification, and combining eq (A-1) and (A-2) we obtain:

$$\frac{d^2 I}{dx^2} - \Gamma^2 I = -YE_H(x) \quad (A-3)$$




Figure A-1. Transmission line parameters.

¹ E. D. Sunde, Earth Conduction Effects in Transmission Systems, Dover Publications, Inc., New York (1967).

Preceding page blank

where Γ is the propagation constant

$$\Gamma = \sqrt{YZ} \quad (A-4)$$

The general solution to eq (A-3) may be written as:

$$I(x) = [A + P(x)]e^{-\Gamma x} - [B + Q(x)]e^{\Gamma x} \quad (A-5)$$

$$V(x) = Z_o [A + P(x)]e^{-\Gamma x} + Z_o [B + Q(x)]e^{\Gamma x} \quad (A-6)$$

where

$$P(x) = \frac{1}{2Z_o} \int_0^x E_H(v) e^{\Gamma v} dv \quad (A-7)$$

$$Q(x) = \frac{1}{2Z_o} \int_0^x E_H(v) e^{-\Gamma v} dv \quad (A-8)$$

$$Z_o = \sqrt{Z/Y} \quad (A-9)$$

The constants A and B are determined by the boundary conditions at the ends of the conductors.

Consider the case when the transmission line is terminated by impedances Z_1 and Z_2 at $x = 0$ and $x = \ell$, respectively. Applying the boundary conditions:

$$V(0) = -I(0)Z_1 \quad (A-10)$$

and

$$V(\ell) = I(\ell)Z_2 \quad (A-11)$$

We obtain:

$$B = \frac{R_2 P(\ell) e^{-2\Gamma \ell} - Q(\ell)}{1 - R_1 R_2 e^{-2\Gamma \ell}} \quad (A-12)$$

$$A = BR_1 \quad (A-13)$$

where R_1 and R_2 are the reflection coefficients at the terminations:

$$R_1 = \frac{Z_1 - Z_0}{Z_1 + Z_0} \quad (A-14)$$

$$R_2 = \frac{Z_2 - Z_0}{Z_2 + Z_0} \quad (A-15)$$

If the electric field vector is constant (in space) along line 2 then eq (A-7) and (A-8) are easily evaluated. Substituting for A, B, P, and Q in eq (A-5) and (A-6) we obtain:

$$I(x) = \frac{E_H}{2\Gamma Z_0} \left\{ \begin{aligned} &2 - (1+R_1)e^{-\Gamma x} - (1+R_2)e^{-\Gamma(\ell-x)} + R_1(1+R_2)e^{-\Gamma(\ell+x)} \\ &+ R_2(1+R_1)e^{-\Gamma(2\ell-x)} - 2R_1R_2e^{-2\Gamma\ell} \end{aligned} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (A-16)$$

and

$$V(x) = \frac{E_H}{2\Gamma} \left\{ \begin{aligned} &-(1+R_1)e^{-\Gamma x} + (1+R_2)e^{-\Gamma(\ell-x)} + R_1(1+R_2)e^{-\Gamma(\ell+x)} \\ &- R_2(1+R_1)e^{-\Gamma(2\ell-x)} \end{aligned} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (A-17)$$

The above solutions for the response have been derived for the field incident along line 2 only. For the total solution, one must combine the solutions for the field incident on each line. The total solution will then be given by equations (A-16) and (A-17), where the driving field E_H is the difference in the fields incident on the two lines. Obviously, a maximum response results when the field propagates in the plane of the two lines.

For a single conductor parallel to a ground plane of infinite conductivity, the modes of propagation for current and voltage along the conductor will be the same as those on a two-wire transmission line defined by the conductor and its image in the ground plane. Equations (A-16) (A-17) can be applied to the case of a single conductor parallel to ground by using the following modifications:

- (1) The electric field incident on the conductor is the net electric field after reflection from the ground plane,
- (2) The characteristic impedance, Z_0 , is the characteristic impedance of the conductor above the ground plane, and
- (3) Equations (A-16) and (A-17) are divided by a factor of two.

CASE II - Incident Electric Field Vector Perpendicular to the
Transmission Line

If an electric field distribution, $E_v(x)$, is incident with the electric field vector perpendicular to the transmission line, equation (A-1) must be modified to include $E_v(x)$ as a source term. With this modification, and combining eq (A-1) and (A-2) we obtain:

$$\frac{d^2 V}{dx^2} - \Gamma^2 V = -ZJ(x), \quad (A-18)$$

where $J(x)$ is the current source density for a spacing, d , between the conductors and an electric field, $E_v(x)$, in the plane of the conductors:

$$J(x) = E_v(x)dy \quad (A-19)$$

The solution to Equation (B-18) may be written as:

$$I(x) = [A+P(x)]e^{-\Gamma x} - [B-Q(x)]e^{\Gamma x} \quad (A-20)$$

$$V(x) = Z_0 [A+P(x)]e^{-\Gamma x} + Z_0 [B-Q(x)]e^{\Gamma x} \quad (A-21)$$

where

$$P(x) = \frac{1}{2} \int_0^x J(v)e^{\Gamma v} dv \quad (A-22)$$

$$Q(x) = \frac{1}{2} \int_0^x J(v)e^{-\Gamma v} dv. \quad (A-23)$$

The constant A and B are determined by the boundary conditions at the ends of the conductors. Consider the case when the transmission line is terminated by impedances Z_1 and Z_2 at $x = 0$ and $x = \ell$, respectively. Applying the boundary conditions, equations (A-10) and (A-11) we obtain:

$$B = \frac{R_2 P(\ell)e^{-2\Gamma \ell} + Q(\ell)}{1 - R_1 R_2 e^{-2\Gamma \ell}} \quad (A-24)$$

$$A = BR_1$$

If the electric field vector is constant (in space) along the transmission line then eq (A-22) and (A-23) are easily evaluated. Substituting for A, B, P and Q in eq (A-20) and (A-21) we obtain:

$$I(x) = \frac{V_d}{2Z_0} \left\{ \begin{aligned} &-(1-R_1)e^{-\Gamma x} + (1-R_2)e^{-\Gamma(\ell-x)} - R_1(1-R_2)e^{-\Gamma(\ell+x)} \\ &+ R_2(1-R_1)e^{-\Gamma(2\ell-x)} \end{aligned} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (A-25)$$

and

$$V(x) = \frac{E_d}{2} \left\{ \begin{aligned} &2-(1-R_1)e^{-\Gamma x} - (1-R_2)e^{-\Gamma(\ell-x)} - R_1(1-R_2)e^{-\Gamma(\ell+x)} \\ &- R_2(1-R_1)e^{-\Gamma(2\ell-x)} \end{aligned} \right\} / (1-R_1R_2e^{-2\Gamma\ell}) \quad (A-26)$$

The solutions derived for the two cases (incident electric field vector parallel and perpendicular to the transmission line) have been stated as single frequency solutions. Fourier analysis or Laplace transform techniques must be used to obtain the solutions for the general case of a transient incident field.